
City of Banning

POOL FENCE BARRIER REQUIREMENTS


THE FOLLOWING SWIMMING POOL BARRIER REQUIREMENTS ARE MANDATED BY THE CALIFORNIA SWIMMING POOL SAFETY ACT. THE ACT ALSO REQUIRES THE SWIMMING POOL CONTRACTOR TO GIVE THE CONSUMER NOTICE OF THESE REQUIREMENTS.



FOOTNOTES:

- 1. If a pool fence barrier is placed between these doors and the pool, these doors need not be equipped with alarms, self-closing or self-latching devices.
- 2. Pools equipped with approved pool safety covers meeting the performance standards of ASTM-F1346 91 need not comply with any of the fence/gate or door provisions.
- 3. Although most fencing configurations have been shown. It is impossible to anticipate the infinite variety and combinations of materials that may be used. Where climbing or "step" conditions may be encountered, check with the Building & Safety Division.
- 4. Existing fences surrounding property at the pool area are permitted if ALL of the following conditions are met:
 - A) The fence is at least 60 inches above grade, measured on the side of the barrier which faces away from the pool.
 - B) The fence has a maximum vertical clearance between grade and the bottom of the barrier of 2 inches, or 4 inches when the grade is a solid impenetrable surface such as concrete.
 - C) The fence has no openings that will allow the passage of a 4-inch sphere.

VARIOUS POOL FENCE TYPES (NOT ALL POSSIBLE POOL FENCE DESIGNS ARE SHOWN, PLEASE CHECK WITH YOUR INSPECTOR FOR MORE INFORMATION)



IF HORIZONTAL MEMBERS ARE LESS THAN 45" APART, VERTICAL SPACING SHALL NOT EXCEED 1-3/4" AND HORIZONTAL MEMBERS SHALL BE ON POOL SIDE.


and fastened at the top and bottom.

RELEASE MECHANISM LOCATED

LESS THAN 54"ABOVE GRADE

IF HORIZONTAL MEMBERS ARE EQUAL TO OR MORE THAN 45" APART, VERTICAL SPACING SHALL NOT EXCEED 4".

* NOTE: Spacing from grade level to bottom of fence, may be 4 inches if grade below fence has a solid impenetrable surface such as concrete.




LATCHING REQUIREMENTS

ALL GATES MUST SWING AWAY FROM POOL, BE SELF-CLOSING & SELF-LATCHING

RELEASE MECHANISM LOCATED

54" OR MORE ABOYE GRADE



Release Mechanism shall be located

at least 60 inches above grade.

TYPICAL SELF-LATCHING GATE and SPRING CLOSER

G: WFFS I FPWN POOL 2 FPW